

Section 614 – Sewer and Water Use Charges

Section 614:00. Regarding Water Meters.

Section 1. Meter Use and Installation. All water use shall be metered and said meters shall be set with the stop and waste valve at least twelve (12) inches, but no more than thirty-six (36) inches above the floor in the room designated for the location of utilities and in which the ceiling is not less than seven (7) feet and six (6) inches high. The meter shall also be installed with a circular obstruction-free area with a radius of eighteen (18) inches so that they can be examined and read, serviced, and provided with suitable protection so that they are made safe from frost and other damage. The meter may not be installed in any manner or location differing from the above standards without prior approval of the Building Inspector. In case of refusal and neglect to set or protect a meter as herein required, the Public Works Superintendent, or its duly authorized agent, shall refuse to turn on water, or, if water has been turned on, it shall be turned off until the consumer shall have complied with said requirements.

Section 2. Effective Date. This Ordinance shall be effective upon its passage and publication.